




SmartGen
ideas for power

HWP40N FORCED CIRCULATION HEATER USER MANUAL



SMARTGEN (ZHENGZHOU) TECHNOLOGY CO., LTD.

3. SPECIFICATION

Table 2 – Parameter Specification

Type	HWP40	
Rated Power	4000W	
Rated Voltage	AC 240V	
Rated Current	16.7A	
Phase	Single phase	
Engine Displacement (L)	15-30	
Thermostat Range	Off: (5~70)°C	On: (0~65)°C
Default Thermostat Range	Off: (40±2)°C	On: (25±2)°C
Overheating Thermostat Range	Off: (95±3)°C	On: Manual
Insulating Resistance	≥50MΩ	
Electrical Strength	AC 1.5kV 1min	
Inlet/Outlet Size	G 3/4 Internal thread (Selectable Φ19.5mm Pagoda header or G 3/4 External thread)	
Max. Water Pressure	0.5MPa	
Pump Flow Velocity	40L/min (1.5m of lift)	
Protection Level	IP44	
Vibration Resistance	(5~8)Hz Amplitude±7.5mm Triaxial	(8~500)Hz a=2g Triaxial
Shock Resistance	Half-sine Wave; a _{peak} =50g; Triaxial	
Working Conditions	-40 °C~+70 °C	
Storage Conditions	-40 °C~+80 °C	
Case Dimensions	414 mm×261 mm×190 mm	
Weight	4.8kg	

4. HEATER INSTALLATION

Please install the heater vertically according to the diagram before use. Pay attention to the direction of heater inlet and outlet, and ensure that the heater position is below the lowest water level of the engine and that all the air is exhausted out of the heater. Perfuse the heater with coolant.




Fig. 1 - Installation Plane Schematic









Fig. 2 - Installation Side Schematic

5. OPERATING INSTRUCTIONS

5.1 BUTTON DESCRIPTION

Table 3 – Panel Display and Buttons

Button	Definition	Description
	Heating	Press and if coolant temperature is below the set cut-off temperature, heater will transfer to auto status; if coolant temperature is above the set cut-off temperature, heater works for 15s and enters auto status after commissioning.
	Stop	Press and heater will stop.
	Set	Press and enter parameter setting menu.
	Up	Display the last digital cube content and do value adjustment.
	Down	Display the next digital cube content and do value adjustment.









5.2 INDICATOR DESCRIPTION

Table 4 - Indicator Description

Sign	Definition	Description
Alarm	Alarm indicator	When lamp is illuminated, heater fault occurs and please decide fault type according to the fault code of digital cube.
Auto/Heat	Auto/Heating	Heater is in auto state when it is flashing; it is in heating state when the lamp is always illuminated.
Stop	Stop indicator	Heater is in stop state when lamp is illuminated.






5.3 DISPLAY ILLUSTRATION

Table 5 - Display Illustration

Sign	Definition	Description
	Cut-off Temperature	The set value of target temperature
	Reset Temperature	The set value of reset temperature
	Current Voltage Value	It is current power voltage when V indicator is light on.
	Accumulated Running Time	It is total running time when 10×Hour indicator is light on; unit is hour, detailed hours are the displayed number x10; e.g. displayed number is 1234, and the actual hours are 12340.
	Accumulated Energy Consumption	It is total energy consumption when 10×kWh indicator is light on; unit is kWh; detailed kWh is the displayed number x10; e.g. displayed number is 456.7, and the actual kWh is 4567.
	Water Flow Sensor Enable	00: Disable; 01: Enable
	Dry Burning Temperature Sensor Enable	00: Disable 01: Enable
	Voltage Protection Enable	00: Disable 01: Enable

5.4 FAULT CODE

Table 6 - Fault Code

Sign	Definition	Description
	Fault Code 1	Dry burning/water shortage protection
	Fault Code 2	Water temperature sensor open circuit
	Fault Code 3	Dry burning temperature sensor open circuit
	Over Voltage	Enters standby status when input voltage is over 264V.
	Under Voltage	Enters standby status when input voltage is over 200V.

5.5 OPERATION PANEL





Fig. 3 – Operation Panel Drawing

5.6 OPERATION DESCRIPTION








➤ Parameter Check

Press  and  to switchover digital cube display and do value adjustment.

➤ Commissioning

If water temperature is above pre-set reset temperature, press  and heater will enter commissioning status, and it will transfer to auto status after heating for 10s.

➤ Parameter Setting

Press  and enter parameter setting menu, and it will display  (H means the set temperature is cut-off temperature value, 40°C is only an example). Press  again to enter the setting, and adjust values by  and . Press  again to move or confirm. Press  and it will go back to the main menu. It will also return back to first page if there is no operation within 1 minute.

6. USE AND MAINTENANCE

- 1) After it is connected with power, heater is at stop state. Press Auto/Heat and make heater enter working status.
- 2) When it needs to be checked/fixed or change pipe or some part, press Stop and make heater enter stop status.
- 3) Before start please confirm whether heater is fully filled with coolant and make gas in the pipe exhausted by vent valve.
- 4) It is strongly suggested to use antifreezing solution with corresponding mark number.
- 5) If ordinary water is used, users must drain the water after stop when environment temperature is below 0°C, in order to prevent the water in the heater getting frozen and resulting in heater fracture.
- 6) GND wire must be earth connected.
- 7) Drain valve: shall be opened or closed by hexagonal flower tool.



Fig. 4 – Vent Valve Indicating Diagram




Fig. 5 Wire Connection




Fig. 6 Vent Valve Size

7. CASE AND DIMENSIONS




Fig. 7 – Overall Dimensions (Unit: mm)

NOTE: all the inlets/outlet connectors are internal thread G 3/4.

8. Pack List

Table 7 - Pack List

No.	Name/Model	Number for one unit
1	Product	1
2	Stand	2
3	Flat Gasket GB/T 95 8	8
4	Spring Washer GB/T 93 8	8
5	Hexagon Nut GB/T 41 M8	8
6	Hexagon Slot GB/T 5783 M8x40	8
7	User Manual	1

Table 8 - Water Gate Accessories

No.	Name/Model	Number for one unit
1	Φ19.5mm Pagoda Joint	2
2	G 3/4 Stainless steel pair screw	2
3	ED Sealing gasket	2




Fig. 8 Pagoda Header Size (Unit: mm)




Fig. 9 Pair Screw Size (Unit: mm)